



Chhatrapati Sambhajnagar. Municipal Corporation  
FIRE BRIGADE  
TELEPHONE NO-2334000-40FAX No-2331444

Outward No:CSMC/AMC/FIRE/1122/2025

Date 30/12/2025

To,  
Medical Superintendent,  
Yunus Fazlani Unani Medical College &  
Al Fazlani Unani Hospital, G.P.No-74,  
At. Kunjkheda Tq. Kannad,  
Dist. Chhatrapati Sambhajnagar.

Sub;- Final Fire Noc is issued to the Yunus Fazlani Unani Medical College, Al Fazlani Unani Hospital, G.P.No-74, At. Kunjkheda Tq. Kannad Dist. Chhatrapati Sambhajnagar.

Ref:- 1) Your Letter date 16/07/2025 2) Provisional Noc on date 10/09/2025  
3) Your Letter date 13/12/2025 4) CFO Inspection on date 25/12/2025

With Reference to the above subject Final Fire Noc is issued to the Yunus Fazlani Unani Medical College & Al Fazlani Unani Hospital, G.P.No-74, At. Kunjkheda Tq. Kannad, Dist. Chhatrapati Sambhajnagar. Plot area 4000.00 Sq.Mtr.

Owner has paid Final Fire Noc Rs. 10,000/- in Fire brigade Receipt No. 13387 date on 30/12/2025.

S.No	Building	Height	Building	Floor	Area of Plot	Builtup Area	Noc Fees	Total Rs
1	Yunus Fazlani Unani Medical College & Al Fazlani Unani Hospital	07.60 Mtr	1	G+1	4000.00 Sq.mtr	3142.74 Sq.mtr	10000	10000
							10000	10000

Following Fire prevention and Fire protection & Fire Fighting measures subject to the Yunus Fazlani Unani Medical College & Al Fazlani Unani Hospital is provided.

1. Open space all around the building is provided for the movement of fire tender and which will carry 25 tons. weight capacity.
2. Underground Water tank 50000 Ltr & Overhead water tank 10000 Ltr, Main Pump – 10 HP- 01 Nos of Suitable capacity for building is Provided.
3. 01 Nos. Fire service inlet 2 way incoming is provided.
4. 02 Nos. Hydrant points all around the building with fire Hose Pipe-02 Nos/ Branch-02 Nos is provided.
5. 01 Nos Wet Riser having outlet on all floors with Hose Pipe -02 Nos/ Branch-02 Nos is Provided.
6. 06 Nos Hose reel of 100 feet on all outlets is provided.
7. Fire Extinguisher of / ABC-06 Kg-10 Nos / Co2-4.5 Kg-01 Nos of suitable Capacity / quantity is provided.
8. 01 Nos Main Staircase 1.50 Mtr is provided.
9. Smoke Detector System-04 Nos is Provided.
- 10 This Certificate shall be treated valid for a period of one year from, the date of issue up to Final Fire Noc

As per BMC ACT -1949 section 376, Development control Rules of 1983 and Maharashtra Fire prevention & Life safety Measures Act 2006 reference to above subject Final Fire Noc is issued to the Medical Superintendent, Yunus Fazlani Unani Medical College, Al Fazlani Unani Hospital, G.P.No-74, At. Kunjkheda Tq. Kannad, Dist. Chhatrapati Sambhajnagar.

Principal

Yunus Fazlani Unani Medical College &  
Al Fazlani Unani Hospital, G.P.No-74,  
At. Kunjkheda Tq. Kannad Dist. Aurangabad 431103

Chief Fire Officer  
Fire Brigade, Municipal Corporation  
Chhatrapati Sambhajnagar.

